

FIRE SAFETY CERTIFICATE

No. MCM/FIRE/2096/2026

Date: 15/07/2026

Certified that the Nutan English School, at Buldhana Road, Malkapur, Dist. Buldhana – 443101 comprised of 1 basement(s) and 3+1 upper floors, owned / occupied by Nutan English School has complied with the fire prevention and fire safety requirements in accordance with rule of State / UT Fire Service Rules, and verified by the officers concerned of Fire Service on 5/07/2026 (date of inspection) in the presence of S. J. Pachpande and that the building / premises is fit for occupancy upto X (X / XII) With effect from 15/07/2026 for a period of one year in accordance with rule and subject to compliance of specific conditions as appended:-

- 1.
- 2.
- 3.
- 4.

Issued on 24/07/2026 (date of issue) at Malkapur (place) by Municipal Fire Officer, Malkapur Municipal Council

*Strike out whichever is not applicable.



Signature with Seal:

For ए. जे. मालकपुर
Name आर. जे. मालकपुर

Designation Municipal Fire Officer

Name & Address of Department/ Office: Fire
Department, Malkapur Municipal Council

To

Nutan English School
Buldhana Road,
Malkapur, Dist. Buldhana – 443101

(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled / annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Pachpande
Manager,
Nutan English School, Malkapur.
Ta. Malkapur, Dist. Buldhana.

Sandeep
Principal,
Nutan English School, Malkapur.
Ta. Malkapur, Dist. Buldhana.



नगर परिषद कार्यालय, मलकापुर

जिल्हा- बुलडाणा (पिन 443101)
अग्निशमन विभाग
comalkapurnp@gmail.com



MCM / FIRE / 2026 / 2026

DATE:- 14 / 07 / 2026

(Fire No – Objection Certificate)

To,

Nutan English School
Buldhana Road,
Malakapur, Dist Buldhana – 443101

Sub : Grand of " Fire No Objection Certificate " for your Educational Building

Ref : 1. Your Application Dated 13/07/2026

2. Certificate Submitted by License Agency Kohinoor safety Services, Mumbai

Vide their letter dated 10/07/2026

This has reference to the above .This office has No Objection for Fire approval for Hospital Building Since the fire fighting arrangements provided is installed by License Agency i.e. Kohinoor safety Services, Mumbai No.MFS/LA/RF-25 RD-27 issued by Directorate of Maharashtra fire Service and has submitted Certificate in " Form A " prescribed in Maharashtra Fire Prevention and life safety Measure rules 2009, this office is issuing a " No Objection Certificate " for your Educational building .

Fire fighting System found in the premises are given below arrangements

Sr.No.	Equipment Installed	Quantity
01	Fire Extinguishers ABC 06 Kg	08
02	Fire Extinguishers Co2 4.5 Kg	01
03	MCP	04
04	Hooter	02
05	Fire Alarm Panel	01
06	D-O-L Starter	01
07	Hydrant Valve	04
08	Hose Box	04
09	Hose Pipe	04
10	Branch Pipe	04

11	Fire Service Inlet	01
12	Hose Reel Hose	08
13	Buster Pump 450 LPM	01

Statutory Provisions Under Maharashtra Fire Prevention and life safety Measure Act ,2006.

1. Undersection 3 of "Maharashtra Fire Prevention and life safety Measure Act ,2006 "(hereinafter referred to as said Act). The applicant shall comply with all the Fire and life safety measures adhering to National Building Code of India ,2016 and as amended from time to time failing which it shall be treated as a violation of the said Act.

2. It is presumed that you have completed the work adhering to the provisions under Section-3 of the said Act.

3. Under sub – section (3) of Section 3, it is responsibility of the Owner or the Occupier as the case maybe, shall furnish to the Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January and July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

4. Under sub section (4) of Section 3, no person shall tamper with, alter, remove or cause any injury or damage to any fire prevention and life safety equipment installed in any such building or part thereof or instigate any person to do so .

The Fire Fighting System provided by you in the premises as per No-Objection Certificate shall be well maintained and shall be kept in tip - top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice and you will be solely responsible to loss of property if any, which may please be noted.

The condition mentioned in the " No - Objection Certificate " will remain unchanged. The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. If any change of Activity or Transfer of Plot or any future expansion, No - Objection Certificate from this office is essential.

(The above NOC is Valid Up to 30/06/2027).




Municipal Fire Officer
Malakapur Municipal Council